



TOWN OF JACKSON

OFFICE OF THE SELECTMEN

COPY

September 23, 2009

Mr. and Mrs. Laurence Siebert
PO Box 90
Jackson, NH 03846

Dear Larry and Marjorie,

As you are aware, during the Selectman's Board meeting on September 17, 2009, your building permit request for a display structure was denied. Jackson's building inspector, Jack Dever, did not recommend granting the permit because the "fence" was over 6 feet tall; therefore, it is considered a "structure." According to building code, a stand alone structure needs an engineered foundation to be installed along with an engineered bracing plan. Also the structure is in violation of the town's setback requirements. In order to proceed with your plans, you will need to obtain a variance from Jackson's Zoning Board. The present chairman is Frank Benesh (tel: 383-8229). After a variance is obtained, you will need to satisfy the foundation and bracing requirements.

Thank you for your cooperation.

Sincerely,

Linda M. Dresch
Town of Jackson